

Date	Invoice #
11/12/2021	63179

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	11/2/2021			

Qty	Item Code	Description	Price Each	Amount
		<p>Repair DH511679</p> <p>301 Paxton Hollow Rd Media PA</p> <p>Date of service 11/2/21 Technician Pat Brady</p> <p>Arrived on site. Station not in alarm, but made momentary alarm chirp at one point. Pulls 6.4 amps. Ran when station filled. Eqd dry.</p> <p>Pulled Dh511679 and found switches in seemingly new condition, and cutter wheel and stator in good working order.brought back to shop for inspection.</p> <p>11/8/21 Pat Pump DH511679 is in shop for Evaluation, and found corroded switches, burnt double red jumper control Bracket and a worn Stator. Motor megs and ohms good. Pump has been repaired and tested in test tank, pump goes in and out of alarm and from on/off 30 seconds at 5.9 amps. Pump is running correctly.</p> <p>Returned to site 11/11/21 and installed customers pump DH511679 and tested. Job complete</p>	<div style="border: 2px solid red; padding: 5px; text-align: center;"> INVOICE REVIEW UPTSA </div> <div style="border: 2px solid red; padding: 5px; text-align: center;"> Okay to PAY Kevin Matson, PE </div> <div style="border: 2px solid red; padding: 5px; text-align: center;"> 12/06/2021 </div>	

All material remains the property of Site Specific Design until final payment.

Total

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Date	Invoice #
11/12/2021	63179

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	11/2/2021			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins	Service Call & Inspection Fee <		
1	Labor-DR	Field Labor Rate for Dylan Rearick	150.00	150.00
2	Labor-PB	Shop Labor rate for Pat	95.00	95.00
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01	95.00	190.00
1	7291	PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02	38.185	38.19
1	1265	CONTROL BRACKET ASM, 240V/60HZ ND0045G01	38.185	38.19
1	8203RE	Stator/liner assy	141.83	141.83
			51.8225	51.82

All material remains the property of Site Specific Design until final payment.

Total

\$705.03

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.