

Date	Invoice #
11/5/2021	63184

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	11/2/2021			

Qty	Item Code	Description	Price Each	Amount
		Repair DH496195 11 Azalea Lane Media Date of service 11/3/21 Technician Dylan Rearick Arrived on site, station in alarm and not running. Power good and meter checks normal. Pulled Dh496195, station full of grease and pine needles. Had Hickman clean out. Pump had corroded switches, but controls and motor good. Cutter wheel worn, and sock wrapped around rotor and split stator. Replaced parts and reinstalled. Pump ran normally, but run light not working on panel.		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
3	Labor-DR	Labor Rate for Dylan Rearick	95.00	285.00
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01	38.185	38.19
1	7291	PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02	38.185	38.19
1	1203	CUTTER WHEEL, FORGED, MACH/HARDENED NC0008P02 PN 1003	72.006	72.01
1	8203RE	Stator/liner assy	51.8225	51.82
1	Pump Truck	Pump truck called out to evacuate station.	325.00	325.00

All material remains the property of Site Specific Design until final payment.

Total

\$960.21

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.