

Date	Invoice #
11/11/2021	63226

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	11/4/2021			

Qty	Item Code	Description	Price Each	Amount
		Replace A237978 with new twp pump DH512178  598 Farnum Road Media, PA  Date of service 11/4/21 Technician John Simons  Arrived on site to find alarm panel broken with water in it due to branch falling from the tree in hitting Panel. Also found that the station was flooded. Replaced panel with a Symplex protect Township panel. Turned the pump on and it did not run. Removed pump A237978 from station and determined that it should be replaced with new Township core due to age and having being rebuilt already once. Installed new pump DH512178 and turned the panel on. The alarm sounded and the station started to pump down. The alarm reset and the pump cycled and shut off. Job complete.		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
2	Labor-DR	Labor Rate for Dylan Rearick	95.00	190.00

All material remains the property of Site Specific Design until final payment.

**Total**

\$340.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

**INVOICE REVIEW  
UPSA**

**Okay to PAY  
Kevin Matson, PE**

**12/06/2021**