

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

Date	Invoice #
11/12/2021	63294

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	11/10/2021			

Qty	Item Code	Description	Price Each	Amount
1 2.5	Service/Ins Labor-JS	Repair DH507245 2217 East Deerfield Drive Media PA Arrived on site to find panel in Alarm and locked out in overpressure. Performed meter test and all readings are correct. Turned breakers off in panel and then turned back on. The pump turned on and amperage climbed to 10 in a matter of five seconds. Released DH507245 from the discharge manifold and cycled in station at 5.5 A. Opened ball valve and had air and blow back which was pressure buildup in line. Called Kevin from Township and he came out to Site. Verified that the shut off valve at the street was open. Kevin requested that we shut the power off to the station and he will contact the Necessary people to repair a line. Turned power off and reinstalled pump. Job complete Service Call & Inspection Fee < Labor rate for John Simons	INVOICE REVIEW UPTSA Okay to PAY Kevin Matson, PE 12/06/2021	150.00 95.00 150.00 237.50

All material remains the property of Site Specific Design until final payment.

Total

\$387.50

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.