

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

Date	Invoice #
12/2/2021	63524

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	12/1/2021			

Qty	Item Code	Description	Price Each	Amount
		Replace A188922 with new Twp pump DH512174 1114 Wooded Way Drive Media PA Date of service 12/2/21 Technician Dylan Rearick Power to panel good, pump not running. Pulled A188922 and found worn out bearings and cracked housing. Pump requires replacement. Pulled dh512174 from township shed and installed in station along with eqd conversion kit. Pump ran at 6.3 amps and shut off successfully		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
2	Labor-DR	Labor Rate for Dylan Rearick	95.00	190.00
1	ND0058G01	Conversion Kit, 2000 Series Tank with Extreme Core Permanent	0.00	0.00
All material remains the property of Site Specific Design until final payment.			Total	\$340.00

**INVOICE REVIEW
UPTSA**

**Okay to PAY
Kevin Matson, PE
12/06/2021**

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.