

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
12/1/2023	72993

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	12/1/2023			
Qty	Item Code	Description			Price Each	Amount
		Christine Cacciola 95 Kingston Rd Media, Pennsylvania 19063-1852				
		Date of service 12/1/23 Technician Pat Brady				
		Arrived on site and found alarm breaker off in panel. Homeowner said it goes off every single day when shower is being used. I ask if he could run the shower to see what is going on. Shower cycled 3 times turned on and shut off 30 seconds at 6.5 amps and all meter readings were correct. Pulled pump for further evaluation and found chunks of grease in station. Cleaned it out the best I could. Everything checked out good with the pump. I explained to customer again about not pouring grease down the drain. He told me it's not from them. Last time we were out here was same thing - bunch of grease in the station and they were running two showers and the washer at the same time.				
1	Service/Ins	Service Call & Inspection Fee <			150.00	150.00
2	Labor-PB	Labor rate for Pat			120.00	240.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.	Subtotal	\$390.00
	Sales Tax (0.0%)	\$0.00
	Total	\$390.00
	Payments/Credits	\$0.00
	Total Due	\$390.00