

# Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001  
(215) 887-3730



# Invoice

Date	Invoice #
12/4/2023	73010

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	12/4/2023			
Qty	Item Code	Description			Price Each	Amount
		Repair DH511430 550 Hillendale Rd Media PA 19063				
<b>OK TO PAY</b> <b>KEVIN MATSON, PE,</b> <b>OPERATIONS MANAGER</b>		Date of service 12/3/23 Technician Pat Brady				
 <b>01-08-2024</b>		Arrived on site and found pump DH511430 in alarm and not pumping out meter readings brown to red were incorrect and amps were low.pulled pump for further evaluation and found worn Stator/cutter wheel and a broken check valve.Replaced parts and installed pump back into station pump goes into and out of alarm and from on/off 33 seconds at 6.2 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee <			150.00	150.00
2	Labor-PB	Labor rate for Pat			120.00	240.00
1	8203	STATOR/LINER ASSY EXTREME NC0039G01			59.43768	59.44
1	1207	REDUNDANT CHECK VALVE ASM w/Rcv 1.50 NPT			141.12085	141.12
1	1203	DW NC0032G03 CUTTER WHEEL, FORGED, MACH/HARDENED NC0008P02 PN 1003			82.29413	82.29

All material remains the property of Site Specific Design until final payment.

<b>Subtotal</b>	\$672.85
<b>Sales Tax (0.0%)</b>	\$0.00
<b>Total</b>	\$672.85
<b>Payments/Credits</b>	\$0.00
<b>Total Due</b>	\$672.85

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.