

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
12/7/2023	73076

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	12/7/2023			
Qty	Item Code	Description			Price Each	Amount
		Replace DH420603 with new twp pump DH870158 1860 Colt Rd Media PA 19063 Service date 12/7/23 Technician Pat Brady Arrived on site and found pump DH420603 In alarm and not pumping out meter readings were incorrect Pulled pump for further evaluation and heavily corroded control/motor housing and EQD was full of water.Due to the age of the pump installed new upper prov core DH870158 and cutt back about a foot of cable on house side and replaced EQD insert.Pump pumped down and shut off at 5.8 amps pump is running correctly				
2	Labor-PB	Labor rate for Pat Service Call & Inspection Fee < EQD INSERT, MALE (SIX PIN)			120.00	240.00
1	Service/Ins				150.00	150.00
1	7095				18.547	18.55

All material remains the property of Site Specific Design until final payment.

All material remains the property of Site Specific Design until final payment.	Subtotal	\$408.55
	Sales Tax (0.0%)	\$0.00
	Total	\$408.55
	Payments/Credits	\$0.00
	Total Due	\$408.55

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.