

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
(215) 887-3730



Invoice

Date	Invoice #
12/11/2023	73110

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	12/11/2023			
Qty	Item Code	Description			Price Each	Amount
OK TO PAY KEVIN MATSON, PE, OPERATIONS MANAGER  01-08-2024		Replace DH433558 with new twp pump DH870154 380 Steeple Chase Dr Media PA 19063 Date of service 12/11/23 Technician Pat Brady Arrived on site and found pump DH433558 in high level alarm and not pumping out. Performed meter readings all were incorrect Pump was pulling 24 amps and shutting off also wires were pulled tight inside the panel.pulled pump for further evaluation and found the rotor locked up .Due to age of pump installed new upper providence core DH870154 pump goes in to and out of alarm and from on/off 30 seconds at 5.8 amps pump is running correctly				
1	Service/Ins	Service Call & Inspection Fee <			150.00	150.00
2	Labor-PB	Labor rate for Pat			120.00	240.00

All material remains the property of Site Specific Design until final payment.

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.

Subtotal	\$390.00
Sales Tax (0.0%)	\$0.00
Total	\$390.00
Payments/Credits	\$0.00
Total Due	\$390.00