

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

OK TO PAY 01/03/2021

Kevin Matson
Operations Manager

Invoice

Date	Invoice #
12/23/2021	63719

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	12/21/2021			

Qty	Item Code	Description	Price Each	Amount
		Repair DH429288 210 Quiet Hollow Rd Media Date of service 12/21/2 Technician Dylan Rearick Arrived on site, pump not running and in high level, would not run when called. Power to panel good, meter checks indicated failed controls. Pulled Dh429288 and found corroded switches, burnt controls, and worn out stator. Replaced parts and reinstalled in station. Pump turned on and pumped out station.		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1	Labor-DR	Labor Rate for Dylan Rearick	0.00	0.00
1	Labor-DR	Labor Rate for Dylan Rearick	95.00	95.00
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01	38.185	38.19
1	7291	PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02	38.185	38.19
1	1265	CONTROL BRACKET ASM, 240V/60HZ ND0045G01	141.83	141.83
1	8203	STATOR/LINER ASSY EXTREME NC0039G01	51.8225	51.82

All material remains the property of Site Specific Design until final payment.

Total

\$515.03

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.