

Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001  
215-887-3730

OK TO PAY KMM -  
02-07-2022

# Invoice

| Date     | Invoice # |
|----------|-----------|
| 1/4/2022 | 62877     |

| Bill To  |
|--|
| Upper Providence Township<br>Attn: Dick Spielman, Sewer Authority<br>935 N. Providence Road<br>Media, PA 19063 |

| Ship To   |
|---|
| Upper Providence Township<br>935 N Providence Road<br>610-566-5376<br>Media, PA 19063 |

| Cust. PO # | Terms  | Rep | Ship Date | Ship Via | Ref # | Project |
|------------|--------|-----|-----------|----------|-------|---------|
|            | Net 30 | PB  | 10/9/2021 |          |       |         |

| Qty  | Item Code | Description  | Price Each   | Amount   |
|--|-----------|--|--------------|----------|
|  |           | Replace A263943 with new Twp pump DH509759<br>431 Kirk Lane<br>Media, PA 19063<br><br>Date of service 10/9/21<br>Technician Pat Brady<br><br>10/9/21 Pat<br>Arrived on site and found pump A263943 in alarm, and<br>not pumping out, took meter readings and all readings<br>were bouncing around, pulled pump<br>to bring back for further evaluation, and put in a site<br>spare. Spare is running correctly goes into and out of<br>alarm, and from on/off<br>32 seconds at 5.8 amps<br><br>Returned to site to retrieve site spare DH508474 and<br>install township pump DH509759<br>Installed pump and tested. System is working properly.<br>Job complete. |              |          |
| 1  | Emergency | Emergency Weekend/After Hours Rate   | 150.00       | 150.00   |
| 1  | Labor-PB  | Emergency Labor rate for Pat   | 145.50       | 145.50   |
| All material remains the property of Site Specific Design until final payment. |           |  | <b>Total</b> | \$295.50 |

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.