

Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001  
215-887-3730

OK TO PAY KMM -  
02-07-2022

Invoice

| Date      | Invoice # |
|-----------|-----------|
| 1/20/2022 | 63817     |

| Bill To   |
|---|
| Upper Providence Township<br>Attn: Kevin Matson, Sewer Authority<br>935 N. Providence Road<br>Media, PA 19063 |

| Ship To   |
|---|
| Upper Providence Township<br>935 N Providence Road<br>610-566-5376<br>Media, PA 19063 |

| Cust. PO # | Terms  | Rep | Ship Date | Ship Via | Ref # | Project |
|------------|--------|-----|-----------|----------|-------|---------|
|            | Net 30 | PB  | 1/4/2022  |          |       |         |

| Qty | Item Code                            | Description  | Price Each | Amount                |
|-----|--------------------------------------|--|------------|-----------------------|
| 1   | Emergency<br>Labor-PB<br>1<br>1<br>1 | DNR DH421299. Install new Twp pump DH512175<br>230 Appletree Dr<br>Media<br><br>Date of service 1/1/22<br>Technician Pat Brady<br><br>Arrived on site and found pump DH421299 in high level<br>alarm, and pulling 26 amps.<br>Pulled pump to bring back for further evaluation, dropped<br>in upper providence spare, DH512175 .cycled pump few<br>times pump is running correctly goes into and out of<br>alarm and from on/off 32 seconds at 6.3 amps.<br><br>1/12/22 Pat<br>Pump DH421299 is in shop for Evaluation , found the<br>switches corroded, burnt control Bracket, and the motor<br>megs bad,pump will need full rebuild or replaced with<br>new core<br><br>1/19/22<br>Township pump assigned to this location, job complete.<br><br>Emergency Weekend/After Hours Rate<br>Emergency Labor rate for Pat<br>Shop Labor rate for Pat |            |                       |
|     |                                      |  |            | <b>Total</b> \$420.50 |

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.