

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
215-887-3730

OK TO PAY KMM -
02-07-2022

Invoice

Date	Invoice #
1/10/2022	63829

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	1/4/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair DH433845 2084 Ridley Creek Rd Media Date of service 1/4/22 Technician Pat Brady 1/3/22 Pat arrived on site and found pump DH433845 in high level alarm and in run dry , pump is not pumping out, and meter checks were incorrect, pulled pump for further evaluation and found station was filled with chunks of grease, and pump had corroded switches, burnt control Bracket , torn Stator and worn cutter wheel. Motor megged and ohm good replaced needed parts returned pump to station, pump is still running continuous . Due to time of day per Scott drop in site's spare and bring there pump back for further evaluation. 1/4/22 Pat Pump DH433845 is in shop for evaluation., and found that the breather tube was crimped up top changed out tube, and pump is running correctly. Pump goes into and out of alarm and from on/off 32 seconds at 5.9 amps. Returned 01/10/21 and installed customer's pump DH433845 and retrieved site's spare. Tested the pump and it operates properly. Job complete		

All material remains the property of Site Specific Design until final payment.

Total

1704 Rockwell Road
Abington, PA 19001
215-887-3730

Date	Invoice #
1/10/2022	63829

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	1/4/2022			

Qty	Item Code	Description	Price Each	Amount
1	1265	CONTROL BRACKET ASM, 240V/60HZ ND0045G01	0.00	0.00
1	1203	CUTTER WHEEL, FORGED, MACH/HARDENED NC0008P02 PN 1003	72.006	72.01
1	Labor-PB	Labor rate for Pat	110.00	110.00
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01	38.185	38.19
1	7291	PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02	38.185	38.19
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1	Labor-PB	Shop Labor rate for Pat	0.00	0.00
1	8203	STATOR/LINER ASSY EXTREME NC0039G01	51.8225	51.82

All material remains the property of Site Specific Design until final payment.

Total

\$460.21

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.