

Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001  
215-887-3730

OK TO PAY KMM -  
02-07-2022

Invoice

Date	Invoice #
1/10/2022	63882

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	1/7/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair DH402897 430 West Rose Tree Rd Media  Date of service 1/7/22 Technician John Simons  Arrived on site to find no alarm but run dry indicated on panel trouble code. Performed meter test and found shorts to ground. Removed Station Lane and opened the EQD connection and found water poured out due to supply cable side cable grip being loose and the dry access flooding at some point previously. Performed Meg test on supply cable and it passed replaced both inserts and supply cable side housing. Removed DH402897 from Station and inspected the switches and they looked brand new. This pump was worked on in October 2020. Returned the pump to Station and had customer run two sinks and the tub. Cycled the pump from alarm and it operates properly at 5.8 amps. Job complete		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1	Labor-JS	Labor rate for John Simons	0.00	0.00
0.5	Labor-JS	Labor rate for John Simons	125.00	62.50
1	1224	PN 1224 ND0058G01 Conversion Kit, 2000 Tank to Extreme Core	39.84878	39.85
1	7094	EQD INSERT, FEMALE (SIX PIN)	14.7285	14.73
1	7095	EQD INSERT, MALE (SIX PIN)	15.8195	15.82

All material remains the property of Site Specific Design until final payment.

**Total**

\$282.90

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.