

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
215-887-3730

OK TO PAY KMM -
02-07-2022

Invoice

| Date | Invoice # |
|-----------|-----------|
| 1/10/2022 | 63896 |

| Bill To |
|--|
| Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063 |

| Ship To |
|---|
| Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063 |

| Cust. PO # | Terms | Rep | Ship Date | Ship Via | Ref # | Project |
|------------|--------|-------|-----------|----------|-------|---------|
| | Net 30 | JohnS | 1/10/2022 | | | |

| Qty | Item Code | Description | Price Each | Amount |
|-----|-------------|---|------------|--------|
| | | Repair DH433508 281 Paxon Hollow Road Media Date of service 1/10/22 Technician John Simons Arrived on site to find alarm panel indicating overpressure. Performed meter test and found floating shorts between one and three (brown and black wires) on the contactor coil. Removed DH433508 from the station. Inspected the switches and found that they were corroded. Inspected the control clip and found that the capacitor had leaked. Performed Meg test on motor and everything checked out OK. Inspected the stator in cutter wheel And found that the stator was good but the impeller was worn. Replaced the switches, control clip, and cutter wheel. Returned the pump to station and tested from Alarm. The station pumped out of Alarm and the pump cycled and shut off. Job complete | | |
| 1 | Service/Ins | Service Call & Inspection Fee < | 150.00 | 150.00 |
| 2 | Labor-JS | Labor rate for John Simons | 110.00 | 220.00 |
| 1 | Consumables | Includes nuts, bolts, washers, glue, tape, wire nuts, terminal flags, pipe dope, teflon tape, locktite, lubricants | 0.00 | 0.00 |
| 1 | 1203 | CUTTER WHEEL, FORGED, MACH/HARDENED NC0008P02 PN 1003 | 72.006 | 72.01 |
| 1 | 1265 | CONTROL BRACKET ASM, 240V/60HZ ND0045G01 | 0.00 | 0.00 |

All material remains the property of Site Specific Design until final payment.

Total

| Date | Invoice # |
|-----------|-----------|
| 1/10/2022 | 63896 |

| Bill To |
|--|
| Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063 |

| Ship To |
|---|
| Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063 |

| Cust. PO # | Terms | Rep | Ship Date | Ship Via | Ref # | Project |
|------------|--------|-------|-----------|----------|-------|---------|
| | Net 30 | JohnS | 1/10/2022 | | | |

| Qty | Item Code | Description | Price Each | Amount |
|-----|-----------|--|------------|--------|
| 1 | 6203 | Seal, Level Sensing Housing Extreme NB0043P01 | 2.182 | 2.18 |
| 1 | 7290 | PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01 | 38.185 | 38.19 |
| 1 | 7291 | PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02 | 38.185 | 38.19 |

All material remains the property of Site Specific Design until final payment.

Total

\$520.57

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.