

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
215-887-3730

OK TO PAY KMM -
02-07-2022

Invoice

Date	Invoice #
1/11/2022	63914

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	1/11/2022			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins 2 Labor-DR 1 8203	Repair DH557362 317 Woodland Ave Media Date of service 1/11/22 Technician Dylan Rearick Arrived on site Dh557362 station flooded, in alarm, and not running. Pump pulls High amps when called. Pulled pump and found stator clogged with washcloth and other fibrous and cloth material, stator split by large amount of non-sewerables. Replaced stator and reinstalled, pump Ran at 6.1 amps and pumped from alarm to successful shutoff. Service Call & Inspection Fee < Labor Rate for Dylan Rearick STATOR/LINER ASSY EXTREME NC0039G01	150.00 110.00 51.8225	150.00 220.00 51.82

All material remains the property of Site Specific Design until final payment.

Total

\$421.82

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all
shipments may be held pending.