

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
215-887-3730

OK TO PAY KMM -
02-07-2022

Invoice

Date	Invoice #
1/12/2022	63930

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JoeS	1/12/2022			

Qty	Item Code	Description	Price Each	Amount
1	UD200A01A01AA	Replace A253988 with new pump DH766940 581 Farnum Rd Media Date of service 1/12/22 Technician Dylan Rearick Arrived on site, station in alarm and not running. Power to panel good, meter checks indicate failed controls. Pulled A253988 from station and found worn out bearings and whooped stator. Motor failed tests. Installed /dh766940 and tested, new core ran normally.	0.00	0.00
1	Installation of Ne...	Core-ug-hw, 240V, CC, 7'C S/N DH766940 Installation of new Extreme Core w/2 yr warranty. Inspect installation, basin, valve and alarm panel. Inspect EQD & wiring. Remove old pump, identify cause of failure, if possible. Provide warranty documentation. Clean grease and debris accumulation in basin. Install new pump core and test, record performance. Dispose of old components and clean work area.	2,588.00	2,588.00

All material remains the property of Site Specific Design until final payment.

Total

\$2,588.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.