

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

Date	Invoice #
11/11/2021	63038

Bill To
Upper Providence Township Attn: Dick Spielman, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	10/21/2021			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins 2 Labor-DR	Replace A139359 with new Twp pump DH512271 557 Rosemary Circle Media, PA Date of service 10/21/21 Technician Dylan Rearick Arrived on site, A139359 running on and off, bearings loud and station not pumping out. Inspected pump and found worn out stator, corroded switches, and capacitor popped and controls burned. Motor failed megging test and bearings rough when spun. Pump needs to be rebuilt or replaced with new township pump. 11/05/21 Returned to site and installed new core from Township DH512271. Tested pump and it operates at 6.2 amps. Job complete NOTE:informed the customer that a clean out cap on lateral line needs to be installed to keep rain water out of system. Service Call & Inspection Fee < Labor Rate for Dylan Rearick	150.00 95.00	150.00 190.00

All material remains the property of Site Specific Design until final payment.

Total

\$340.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.