

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

Date	Invoice #
2/9/2022	64206

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	2/7/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair DH510071 120 Paxon Hollow Rd Media PA Date of service 2/7/22 Technician Jon Smith 2/06/22: Per Jon Smith's "On Call Notes" : Emergency service. Pump in alarm and not running. Installed site spare. 2/8/22 Pat Pump DH510071 is in shop for Evaluation, and found corroded switches, burnt control Bracket, and the rotor was jammed with rags, cutter wheel and stator is worn. 2/8/22 Pat pump has been repaired and tested in test tank, pump goes into and out of alarm and from on/off 32 seconds at 5.8 amps pump is running correctly 02/09/22 returned to site and retrieved Site spare and installed DH510071. Manually tested and it operates properly. Job complete		
1	Emergency	Emergency Weekend/After Hours Rate	165.00	165.00
1	labor-JJ	Labor rate for Jonathan Smith	145.50	145.50
2	Labor-PB	Shop Labor rate for Pat	110.00	220.00
1	1265	CONTROL BRACKET ASM, 240V/60HZ ND0045G01	150.34526	150.35

All material remains the property of Site Specific Design until final payment.

Total

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Date	Invoice #
2/9/2022	64206

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	2/7/2022			

Qty	Item Code	Description	Price Each	Amount
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01	38.185	38.19
1	7291	PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02	38.185	38.19
1	8203	STATOR/LINER ASSY EXTREME NC0039G01	48.88976	48.89
1	1203	CUTTER WHEEL, FORGED, MACH/HARDENED NC0008P02 PN 1003	72.006	72.01
1	6203	Seal, Level Sensing Housing Extreme NB0043P01	2.18306	2.18

All material remains the property of Site Specific Design until final payment.

Total

\$880.31

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.