

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

Date	Invoice #
2/14/2022	64286

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	2/14/2022			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins 1 Labor-JS 1 1224	Replace A237951 with new Twp pump DH512169 344 State Rd Media Date of service 2/14/22 Technician John Simons Arrived on site to find A237951 not operating and in Alarm. The pump has been serviced before. Replaced the pump with new Township core DH512169 and used a 1224 adapter due to the age of pump. Turned the pump on and the station pumped out of alarm and the pump cycled and shut off. Job complete Service Call & Inspection Fee < Labor rate for John Simons PN 1224 ND0058G01 Conversion Kit, 2000 Tank to Extreme Core	150.00 110.00 41.458	150.00 110.00 41.46

All material remains the property of Site Specific Design until final payment.

Total

\$301.46

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.