

Date	Invoice #
2/17/2022	64341

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	2/17/2022			

Qty	Item Code	Description	Price Each	Amount
1	Labor-PB 1 Service/Ins	Repair DH497176 141 Lakeview Drive Media PA 19063 Date of service 2/17/22 Technician Pat Brady 2/17/22 Pat Arrived on site and found pump DH497176 alarm light on on the panel but no Buzzer, and none of the trouble lights were lit up on the panel, I megged cable cable was good tighten all the wires up in the panel all we're good except the jumper wire it was not up in the Slot all the way, I tighten the jumper wire down turn power back on everything is running normal Labor rate for Pat Service Call & Inspection Fee <	110.00 150.00	110.00 150.00

All material remains the property of Site Specific Design until final payment.

Total

\$260.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.