

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
215-887-3730

Invoice

Date	Invoice #
2/22/2022	64381

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	2/21/2022			

Qty	Item Code	Description	Price Each	Amount
		Replace DH397335 with new Twp pump DH770940 210 Sycamore Mills Road Media, PA Date of service 2/21/22 Technician John Simons Arrived on site to find station in Alarm and pump running continuously. Removed pump DH397335 from Station and found that the wet well was full of wipes. Called Hickman Sanitation out to clean station. Determined that pump had bad switches, control clip, cutter wheel and stator. Also the casting was falling apart. Spoke with Joe Speese and he said to replace pump. Retrieved new Township pump DH770940 from shed and left outside of station for Hickman Sanitation to install once station is cleaned. Job complete Note: Informed the customer is it sanitary napkins and wipes should not be flushed		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1.5	Labor-JS	Labor rate for John Simons	110.00	165.00
1	Pump Truck	Pump truck called out to evacuate station.	416.00	416.00
All material remains the property of Site Specific Design until final payment.			Total	\$731.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.