

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
215-887-3730

UPTSA - 04-08-22

OK TO PAY

Kevin

Matson, Ops. Mgr.



Invoice

Date	Invoice #
3/11/2022	64546

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	3/5/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair DH387369 380 West Rose Tree Rd Media Date of service 3/5/22 Technician Dylan Rearick 3/5-22 Station indicated overpressure, Dh387369 pulled due to failed controls and spare installed 3/8/22 Inspected pump. Motor bad, full rebuild required. Needs new barb fitting as well. Return to site 03/11/22 and retrieved site spare and installed new Township pump DH770991. Manually ran and it operated properly. Job complete		
1	Emergency	Emergency Weekend/After Hours Rate	165.00	165.00
1	Labor-DR	Emergency Labor Rate for Dylan Rearick	145.50	145.50
1	Labor-DR	Field Labor Rate for Dylan Rearick	110.00	110.00

All material remains the property of Site Specific Design until final payment.

Total

\$420.50

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.