

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
215-887-3730

UPTSA - 04-08-22
OK TO PAY

Kevin 
Matson, Ops. Mgr.

Invoice

Date	Invoice #
3/24/2022	64800

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	3/24/2022			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins 2 Labor-JS 1 1224	Replace A237657 with new Twp pump DH770936 509 Old State Rd Media Date of service 3/24/22 Technician John Simons Arrived on site to find Station in Alarm and A237657 not running. Removed pump from station and installed new Township core DH770936 with a 1224 adapter because the existing core is 16 years old. Tested pump from alarm and it operates properly. The alarm cleared and the pump cycled and shut off. Job complete Service Call & Inspection Fee < Labor rate for John Simons PN 1224 ND0058G01 Conversion Kit, 2000 Tank to Extreme Core	150.00 110.00 41.458	150.00 220.00 41.46

All material remains the property of Site Specific Design until final payment.

Total

\$411.46

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.