

Date	Invoice #
3/30/2022	64825

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	3/25/2022			

Qty	Item Code	Description	Price Each	Amount
3.5	Labor-PB 1 7094 1 Pump Truck	Replace DH385751 with new Twp pump D771066 219 West Rose Tree Rd Media Date of service 3/25/22 Technician Pat Brady Pat arrived on site and found pump in over pressure alarm,reset the breakers ,the panel went back to normal no alarm pump started to pump out of station.Open lid to station and it was completed full of sludgePulling pump for further evaluation and found flooded motor,corroded switches, burnt contactor and motor megs bad.There is a hole on the pump cable that allowed water to get into control housing and flooded out the motor. Station has been pumped out by Hickman sanitation. I installed new Upper Providence pump.S/N DH771066. New core has been installed cycled and running correctly pump goes into and out of alarm and from on/off 34 seconds at 5.8 amps. Also secured panel to the wall and changed out the EQD Labor rate for Pat EQD INSERT, FEMALE (SIX PIN) Pump truck called out to evacuate station.	110.00 14.7285 322.00	385.00 14.73 322.00

All material remains the property of Site Specific Design until final payment.

Total

\$721.73

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.