

Date	Invoice #
3/31/2022	64900

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	3/31/2022			

Qty	Item Code	Description	Price Each	Amount
1 2	Service/Ins Labor-PB	Replace A293631 with new Twp pump DH770913 5 Ruskin Lane Media PA Date of service 3/31/22 Technician Pat Brady Pat arrived on site and found pump A293631 not in alarm.Took meter readings and pump was Pulling 28-27 amps.Pulling pump for further evaluation, and found that the pump has bad bearings, and motor megs bad pump will need full rebuild or replaced with new core. I spoke with Anthony and we are going to install new townships pump .DH770913 has been in and running correctly. Service Call & Inspection Fee < Labor rate for Pat	150.00 110.00	150.00 220.00

All material remains the property of Site Specific Design until final payment.

Total

\$370.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.