

Date	Invoice #
4/14/2022	65067

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	4/14/2022			

Qty	Item Code	Description	Price Each	Amount
1.5	Service/Ins Labor-PB	Replace A139358 with new Twp pump DH781024 578 Rosemary Circle Media PA Date of service 4/14/22 Technician Pat Brady Arrived on site and found pump A139358 in alarm, and Not running, and bad readings across the board. Pulled pump for further evaluation and found top control cover is cracked which Allowed water to flood the controls, and the motor. Per Anthony dropping in upper providence township pump DH781024 in new core cycled pump few times, pump goes into and out of alarm and from on /off 34 seconds at 5.8 amps pump is running correctly Service Call & Inspection Fee < Labor rate for Pat	150.00 110.00	150.00 165.00

All material remains the property of Site Specific Design until final payment.

Total

\$315.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.