

Site Specific Design, Inc.

1704 Rockwell Road  
Abington, PA 19001  
215-887-3730

# Invoice

Date	Invoice #
4/14/2022	65070

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	4/14/2022			

Qty	Item Code	Description	Price Each	Amount
		DH511314 2165 North Providence Rd Media, PA  Date of service 4/14/22 Technician Pat Brady  Arrived on site and found pump not in alarm and breakers off .turn breakers back on,Took meter readings and all readings were correct had customer run water a couple of times Pump goes in and out of alarm and from on/off 30 seconds at 6.0 amps pump is running correctly..		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1	Labor-PB	Labor rate for Pat	110.00	110.00
All material remains the property of Site Specific Design until final payment.			<b>Total</b>	\$260.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.