

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Date	Invoice #
5/6/2022	63505

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	11/30/2021			

Qty	Item Code	Description	Price Each	Amount
		<p>Replace A152035 with new Twp pump DH512323 781 Ridley Creek Rd Media PA</p> <p>Date of service 11/30/21 Technician John Simons</p> <p>Arrived on site to find pump A152035 in alarm and not running removed pump and installed spare, pump needs full rebuild so a new pump will be installed as a replacement.</p> <p>Returned to site 12/01/21 and installed Township core DH512323 with a 1224 adapter to replace the existing core A152035. Tested the pump and it operates properly. Need to return and install a township protect panel per Kevin Matson.</p> <p>Returned to site 03/04/22 to replace existing panel with Simplex protect panel provided by township. Determined that the main supply feed was coming through the back upper right hand corner of panel and that the panel is installed in stucco. Need to have an electrician re-run the main power feed so that it can penetrate through the bottom of the panel. At this point we cannot install it until this is done. Informed Kevin Matson and the customer of this.</p> <p>Currently the redundant run feature is removed from the printed circuit board due to water entering Panel through</p>		
				Total

Date	Invoice #
5/6/2022	63505

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	11/30/2021			

Qty	Item Code	Description	Price Each	Amount
1		the penetration through back. The panel is not in great shape.		
1	Emergency	The homeowners names are Ryan and Trish.		
1	Labor-SG	Ryan's #717 817-3321. Trish's #302 521-6412		
1	1224	Emergency Weekend/After Hours Rate	165.00	165.00
1		Emergency Labor Rate (per hour) - Scott	110.00	110.00
1		PN 1224 ND0058G01 Conversion Kit, 2000 Tank to Extreme Core	41.458	41.46
1	Labor-JS	Field Labor rate for John Simons	110.00	110.00
1	Misc40700	Misc parts needed for service	35.00	35.00
			Total	\$461.46

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.