

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Date	Invoice #
5/4/2022	65292

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	5/4/2022			

Qty	Item Code	Description	Price Each	Amount
1 3	Service/Ins Labor-PB	Replace DH402854 with new Twp pump DH781256 270 West Rose Tree Rd.,Media, PA. 19063 Date of service 5/4/22 Technician Pat Brady Arrived on site and found pump DH402854 in high level alarm, and over pressure,meter readings were all incorrect, and pump was pulling 25 amps.Pulling pump for further evaluation,found switches are corroded blown capacitor and motor megs bad, Also station was full of chunks of grease, Cleaned out station installed upper providence new pump DH781256 pump goes into and out of alarm and from on/off 34 seconds at 5.8 amps pump is running correctly.Station will need 6" riser Service Call & Inspection Fee < Labor rate for Pat	150.00 110.00	150.00 330.00

All material remains the property of Site Specific Design until final payment.

Total

\$480.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.