

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

Date	Invoice #
5/5/2022	65300

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	5/4/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair 433582 223 Yarmouth Lane, Media, PA. 19063 (Craig Gamber) Date of service 5/4/22 Technician Dylan Rearick Arrived on site, station running off alarm. Pulled pump and inspected, switches flooded by clogged level sensing housing causing loss of level. Switches wet and corroding, replaced with new set and tested pump successfully.		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1	Labor-DR	Labor Rate for Dylan Rearick	0.00	0.00
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01	38.185	38.19
1	7291	PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02	38.185	38.19
All material remains the property of Site Specific Design until final payment.			Total	\$226.38

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.