

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

Date	Invoice #
5/10/2022	65361

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	5/10/2022			

Qty	Item Code	Description	Price Each	Amount
1.5	Service/Ins Labor-PB	DH770958 113 Cove Lane, Media, PA. 19063 Date of service 5/10/22 Technician Pat Brady 5/10/22 Pat arrived on site and found breakers were shut off to the pump,turn breaker's back on and pump DH770958 was in high level alarm, and pulling 6.1 amps. Took meter readings and they were incorrect.Pulled pump for further evaluation, and found equalizer was push out a little bit ,and the discharge hade a bunch of what looked like seeds,I open up the valve to clean discharge out nd the stuff shot out.I examine the pump and the control Bracket, switches ,and stator are good, and operating properly, Pump goes into and out of alarm, and from on/off 32 seconds at 6.1 amps pump is running correctly. Service Call & Inspection Fee < Labor rate for Pat	150.00 110.00	150.00 165.00

All material remains the property of Site Specific Design until final payment.

Total

\$315.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.