

Site Specific Design, Inc.**Abington, PA 19001**
215-887-3730**Invoice**

Date	Invoice #
5/17/2022	65454

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JoeS	5/17/2022			

Qty	Item Code	Description	Price Each	Amount
1	UD100A01A01AA	Replace A139337 with new pump DH784303 1115 Wooded Drive Media, PA 19063 Date of service 5/17/22 Technician Dylan Rearick Arrived on site. Station in alarm and it running, pulled pump, bearings locked up and motor failed. Old pump A139337/new pump dh784303 Installed new core per township direction due to age of pump and cost of repair and tested successfully.	0.00	0.00
1	Installation of Ne...	D series upgrade core, extreme, 240V, 7' core cable, candy cane discharge S/N DH784303 Installation of new Extreme Core w/2 yr warranty. Inspect installation, basin, valve and alarm panel. Inspect EQD & wiring. Remove old pump, identify cause of failure, if possible. Provide warranty documentation. Clean grease and debris accumulation in basin. Install new pump core and test, record performance. Dispose of old components and clean work area.	2,588.00	2,588.00
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1	Labor	Vendor Service	110.00	110.00
1	1265	CONTROL BRACKET ASM, 240V/60HZ ND0045G01	0.00	0.00
-1	1266	Control Bracket Assembly 120 Volt/60 HZ ND0045G02	0.00	0.00

All material remains the property of Site Specific Design until final payment.

Total

\$2,848.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.