

Site Specific Design, Inc.

*1704 Rockwell Road
Abington, PA 19001
215-887-3730*

Invoice

Date	Invoice #
5/18/2022	65473

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref#	Project
	Net 30	PB	5/18/2022			

Qty	Item Code	Description	Price Each	Amount
		<p>Evaluate DH472939 2560 North Providence Road Media, PA 19063</p> <p>Date of service 5/18/22 Technician Pat Brady</p> <p>Arrived on site and found pump DH472939 not in alarm, Took meter readings all readings were correct. I ran pump into alarm with homeowner garden hoses, pump pump out of alarm and on/off 34 seconds at 6.2 amps. I asked homeowner what happen, and he said water was backing up into his basement. He called a plumber and he said that the pump wasn't working.. I ask homeowner to run water and determined that the inlet was clogged, unclogged the inlet with my wrench and and pump is running as it should</p>		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1	Labor-PB	Labor rate for Pat	110.00	110.00

All material remains the property of Site Specific Design until final payment.

Total

\$260.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.