

Site Specific Design, Inc.**Abington, PA 19001**
215-887-3730**Invoice**

Date	Invoice #
5/24/2022	65538

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	5/24/2022			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins 2 Labor-DR	Replace DH402768 with new Twp pump DH781257 310 Sycamore Mills Rd Media PA Date of service 5/24/22 Technician Dylan Rearick Dh402768/new core dh781257 Arrived on site, station flooded, power to panel good but meter checks show failed controls. Pulled Dh402768 and found it running contously, capacitor popped and motor failed testing, requires full rebuild or replacement. Installed new core as replacement due to age and condition of pump. New core pumped down and shut off successfully. Service Call & Inspection Fee < Labor Rate for Dylan Rearick	150.00 110.00	150.00 220.00

All material remains the property of Site Specific Design until final payment.

Total

\$370.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all
shipments may be held pending.