

Site Specific Design, Inc.**Abington, PA 19001**
215-887-3730**Invoice**

Date	Invoice #
6/1/2022	65591

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	6/1/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair DH511466 Spoke with customer who happened to work for the Township and he said the alarm sounded for about a minute and then shut off. Had the customer run water and the pump never went into alarm and cycled several times, which is what it would normally do. The station was installed in November 2021. Removed the pump from Station and inspected the switches and the rivet points has slight corrosion on them. Replaced both switches and verified that the control clip worked properly. Returned the pump to Station and tested from Alarm. The alarm reset and the pump cycled and shut off. Job complete		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1	Labor-JS	Labor rate for John Simons	110.00	110.00
1	Consumables	Includes nuts, bolts, washers, glue, tape, wire nuts, terminal flags, pipe dope, teflon tape, locktite, lubricants	11.4555	11.46
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01	38.185	38.19
1	7291	PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02	38.185	38.19

All material remains the property of Site Specific Design until final payment.

Total

\$347.84

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.