

Site Specific Design, Inc.

*Abington, PA 19001
215-887-3730*

Invoice

Date	Invoice #
5/31/2022	65618

Bill To Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Ship To Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063
---	---

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	5/31/2022			

Qty	Item Code	Description	Price Each	Amount
		<p>Replace A237673 with new Twp pump DH791723 640 Farnum Rd Media PA 19063</p> <p>Date of service 5/31/22 Technician Pat Brady</p> <p>Arrived on site and found pumpA237673 grinding very loud, and all readings were incorrect. pulled pump and the control housing and motor housing bolt holes are corroded through. installed a upper providence new core DH791723 cycled pump couple times pump goes into and out of alarm and from on/off 33 seconds at 5.8 amps pump is running correctly</p>		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1	Labor-PB	Labor rate for Pat	110.00	110.00

All material remains the property of Site Specific Design until final payment.

Total

\$260.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.