

**Site Specific Design, Inc.****Abington, PA 19001**  
**215-887-3730****Invoice**

Date	Invoice #
5/31/2022	65619

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	5/31/2022			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins 1 1 Labor-PB	Repair DH465308 181 Damview Dr Media PA  Date of service 5/31/22 Technician Pat Brady  Arrived on site and found pump DH465308 no in alarm ,all meter readings were correct . I open station and the bladder hose was not connected. Connected the hoses had homeowner run water . Pump is running correctly goes into and out of alarm and from on/off 33 seconds at 6.1 amps .  Service Call & Inspection Fee < Labor rate for Pat	150.00 110.00	150.00 110.00

All material remains the property of Site Specific Design until final payment.

**Total**

\$260.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.