

## *Site Specific Design, Inc.*

## Invoice

*1704 Rockwell Road  
Abington, PA 19001  
215-887-3730*

Date	Invoice #
6/1/2022	65578

<b>Bill To</b>  Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	<b>Ship To</b>  Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063
---	---

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	5/26/2022			

Qty	Item Code	Description	Price Each	Amount
		<p>2322 West Deerfield Dr Media</p> <p>Date of service 5/26/22 Technician Pat Brady</p> <p>Arrived on site and pump wasn't in alarm, homeowner said we were just out here 5/24/22 and did a bunch of stuff.I ask her if she could run some water, and the alarm went off . Pump is running off of the alarm switch. Pulled pump for further evaluation and found the wires came lose.Put all new butt connectors on both switches,installed pump back into station,cycled the pump couple of times,,pump goes into and out of alarm and from on/off 34 seconds at 6.0 amps pump is running correctly</p>		
1	Service/Ins	Service Call & Inspection Fee <	0.00	0.00
1	Labor-PB	Labor rate for Pat	0.00	0.00

All material remains the property of Site Specific Design until final payment.

Total

\$0.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.