

1704 Rockwell Road
Abington, PA 19001
215-887-3730

Date	Invoice #
6/3/2022	65664

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	6/3/2022			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins 2 Labor-PB	Replace DH424934 with new Twp pump DH791727 Address: 275 Marcella Lane, Media, Pa. 19063 (Anil Murthy) Date of service 6/3/22 Technician Pat Brady Arrived on site and found pump DH424934 in high level alarm, and not running, all meter readings were incorrect. Pulled pump for further evaluation and found station flooded, control cover, and motor housing bolt holes corroded through. Replaced pump with new upper providence pump DH791727 pump has been installed and cycled pump goes into and out of alarm and from on/off 32 seconds at 5.8 amps pump is running correctly Service Call & Inspection Fee < Labor rate for Pat	150.00 110.00	150.00 220.00

All material remains the property of Site Specific Design until final payment.

Total

\$370.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.