

**Site Specific Design, Inc.****Abington, PA 19001**  
**215-887-3730****Invoice**

Date	Invoice #
6/6/2022	65690

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	6/6/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair DH511204 420 Hillendale Rd Media, PA  Date of service 6/6/22 Technican Dylan Rearick  Arrived on site, power to panel fine and meter readings normal. Pump in alarm when powered on.  Pulled Dh511204 and inspected. Switches corroded, replaced. Stator worn, replaced. Motor controls and testing fine, reinstalled pump and pumped out station, job complete.!		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
2	Labor-DR	Labor Rate for Dylan Rearick	110.00	220.00
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01	38.185	38.19
1	7291	PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02	38.185	38.19
1	8203	STATOR/LINER ASSY EXTREME NC0039G01	51.8225	51.82

All material remains the property of Site Specific Design until final payment.

**Total**

\$498.20

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all  
shipments may be held pending.