

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

Date	Invoice #
6/9/2022	65760

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	6/9/2022			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins 1 1	Repair DH648200 1109 Wooded Way Media PA Date of service 6/9/22 Technician Dylan Rearick Arrived on site, power to panel normal, and meter checks are fine. Pulled Dh648200, station clean and free of non-sewerables. Checks switches, stator, and controls on pump, everything normal. Reinstalled pump and attempted to contact homeowner to run water and test station, but no one answered door when it was knocked and doorbell rang repeatedly. Pump runs when manually called, and no odor of sewage present, but entire yard inundated with rain water. Job complete. Service Call & Inspection Fee < Labor Rate for Dylan Rearick	150.00 110.00	150.00 110.00

All material remains the property of Site Specific Design until final payment.

Total

\$260.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.