

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

Date	Invoice #
6/10/2022	65785

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	6/10/2022			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins 2 Labor-PB	Replace DH391476 with new Twp pump DH791744 Address: 385 Sycamore Mills Rd., Media, PA. 19063 (Nathalia Idarraga) Date of service 6/10/22 Technican Pat Brady Arrived on site and found pump DH391476 not in alarm, and all meter readings were correct, but pump was pulling 4.3amps. Pulled pump for further evaluation and found the stator, control bracket and switches were ok. Motors ohms are bad. put in upper providence pump DH791744 pump goes into and out of alarm and from on/off 32 seconds at 5.8 amps pump is running correctly 1 Service Call & Inspection Fee < 2 Labor rate for Pat	150.00 110.00	150.00 220.00

All material remains the property of Site Specific Design until final payment.

Total

\$370.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.