

**Site Specific Design, Inc.**

**1704 Rockwell Road  
Abington, PA 19001  
215-887-3730**

**Invoice**

Date	Invoice #
6/30/2022	65970

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	6/27/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair Dh770936 509 Old State Road Media, PA 19063		
		Date of service 6/26/22 Technician Dylan Rearich		
		Arrived on site, power to panel good, station not in alarm. Pulled core and installed spare, water comes out of ground near supply cable inlet when pump runs. Bringing pump back to shop, system has discharge issues, township needs to dig up discharge and figure out why it is leaking.		
		6/29/22 Inspection of pump found switches, motor controls, and motor in good working order. Stator and cutter wheel also fine, although sandy abrasives present inside stator. Cleaned out suction housing and tested pump several times to ensure proper function, ready to return to system.		
		6/30/22 Pat returned pump DH779036 to station and pump goes into and out of alarm and from on/off 33 seconds at 5.9 amps pump is running correctly.		
1	Emergency	Emergency Weekend/After Hours Rate	165.00	165.00
1	Labor-DR	Emergency Labor Rate for Dylan Rearick	165.00	165.00
1	Labor-DR	Shop Labor Rate for Dylan Rearick	110.00	110.00

All material remains the property of Site Specific Design until final payment.

**Total**

\$440.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all  
shipments may be held pending.