

Site Specific Design, Inc.

**1704 Rockwell Road
Abington, PA 19001
215-887-3730**

Invoice

| Date | Invoice # |
|----------|-----------|
| 7/5/2022 | 66057 |

| Bill To |
|---|
| Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063 |

| Ship To |
|---|
| Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063 |

| Cust. PO # | Terms | Rep | Ship Date | Ship Via | Ref # | Project |
|------------|--------|-------|-----------|----------|-------|---------|
| | Net 30 | JohnS | 7/5/2022 | | | |

| Qty | Item Code | Description | Price Each | Amount |
|--|-------------|---|--------------|--------|
| | | Repair DH420603 1860 Colt Road Media, PA 19063 Date of service 7/5/22 Technician John Simons Arrived on site due to customer stating that the pump went into alarm on Saturday but hasn't since. Performed meter test and all readings were correct. Had customer run two sinks and a tub and the pump turned on and shut off at about 50 seconds. Removed pump DH420603 from Station and inspected the cutter wheel and stator. The cutter wheel had no teeth in the stator was worn due to age. Inspected the switches and they were corroded. Verified the motor and control clip are good. Replaced the switches, stator, and cutter wheel. Returned the pump to station and tested from Alarm. The pump operates properly. Job complete | | |
| 1 | Service/Ins | Service Call & Inspection Fee < | 150.00 | 150.00 |
| 1 | Labor-JS | Labor rate for John Simons | 0.00 | 0.00 |
| 0.5 | Labor-JS | Labor rate for John Simons | 110.00 | 55.00 |
| 1 | 1203 | CUTTER WHEEL, FORGED, MACH/HARDENED NC0008P02 PN 1003 | 72.006 | 72.01 |
| 1 | 6203 | Seal, Level Sensing Housing Extreme NB0043P01 | 2.18306 | 2.18 |
| 1 | 7290 | PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01 | 38.185 | 38.19 |
| All material remains the property of Site Specific Design until final payment. | | | Total | |

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001
215-887-3730

Invoice

| Date | Invoice # |
|----------|-----------|
| 7/5/2022 | 66057 |

| Bill To |
|---|
| Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063 |

| Ship To |
|---|
| Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063 |

| Cust. PO # | Terms | Rep | Ship Date | Ship Via | Ref # | Project |
|------------|--------|-------|-----------|----------|-------|---------|
| | Net 30 | JohnS | 7/5/2022 | | | |

| Qty | Item Code | Description | Price Each | Amount |
|--|-------------|---|--------------|----------|
| 1 | 7291 | PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02 | 38.185 | 38.19 |
| 1 | 8203 | STATOR/LINER ASSY EXTREME NC0039G01 | 51.8225 | 51.82 |
| 1 | Consumables | Includes nuts, bolts, washers, glue, tape, wire nuts, terminal flags, pipe dope, teflon tape, locktite, lubricants | 0.00 | 0.00 |
| All material remains the property of Site Specific Design until final payment. | | | Total | \$407.39 |

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.