

Date	Invoice #
7/7/2022	66105

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	7/7/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair DH429420 Address: 205 Coventry Lane, Media , PA. 19063- (Anne Fenerty) Date of service 7/7/22 Technician John Simons Arrived on site to find station in alarm and pump DH429420 not running. Performed meter test and all readings were correct. Removed pump from station and inspected the switches, control clip, performed meg test on motor, inspected lower suction housing and cutter wheel. Determined that the control clip thermal overload failed. The Meg test found all readings to be good. The cutter wheel was worn but the stator was good. The switches were slightly corroded. Replaced the switches, and control clip. Replaced cutter wheel with a good used one. Returned the pump to station and the alarm cleared after a few minutes and the pump cycled at 6.8 amps and shut off. Job complete		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
1	Labor-JS	Labor rate for John Simons	0.00	0.00
0.5	Labor-JS	Labor rate for John Simons	110.00	55.00
1	Consumables	Includes nuts, bolts, washers, glue, tape, wire nuts, terminal flags, pipe dope, teflon tape, locktite, lubricants	0.00	0.00
1	6203	Seal, Level Sensing Housing Extreme NB0043P01	2.18306	2.18
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01	38.185	38.19

All material remains the property of Site Specific Design until final payment.

Total

1704 Rockwell Road
Abington, PA 19001
215-887-3730

Date	Invoice #
7/7/2022	66105

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	7/7/2022			

Qty	Item Code	Description	Price Each	Amount
1	7291	PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02	38.185	38.19
1	1265	CONTROL BRACKET ASM, 240V/60HZ ND0045G01	0.00	0.00

All material remains the property of Site Specific Design until final payment.

Total

\$283.56

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.