

1704 Rockwell Road
Abington, PA 19001
215-887-3730

Date	Invoice #
7/22/2022	66328

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	7/22/2022			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins	Replace DH419303 with new Twp pump DH799230 1931 Colt Rd Media PA Date of service 7/22/22 Technicna Pat Brady Arrived on site and found station below grade and pump DH419303 in high level alarm,all meter readings are incorrect.Pulled pump for further evaluation and found corroded switches blown capacitor and motor megs bad.Installed a upper providence new core DH799230 and pump is running correctly goes into and out of alarm and from on/off 33 seconds at 5.4 amps also station is below grade needs a 6" riser		
2	Labor-PB	Service Call & Inspection Fee < Labor rate for Pat	150.00 110.00	150.00 220.00

All material remains the property of Site Specific Design until final payment.

Total

\$370.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.