

**Site Specific Design, Inc.**

**1704 Rockwell Road  
Abington, PA 19001  
215-887-3730**

**Invoice**

Date	Invoice #
8/10/2022	66442

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	DR	8/8/2022			

Qty	Item Code	Description	Price Each	Amount
1	Emergency 1 Labor-DR 1 1264	DH383401 177 West Rose Tree Road Media, PA 19063  Date of service 8/8/22 Technician Dylan Rearick  Wasps taken care of. Power to panel good and pump runs when called but water can be heard flowing back. Pulled pump and found broken check valve. Replaced and reinstalled pump, system runs normally now. Job complete.  Emergency Weekend/After Hours Rate Emergency Labor Rate for Dylan Rearick Anti Syphon check valve assembly for Drywell NC0032G01	165.00 165.00 111.282	165.00 165.00 111.28

All material remains the property of Site Specific Design until final payment.

**Total**

\$441.28

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.