

1704 Rockwell Road  
Abington, PA 19001  
215-887-3730

Date	Invoice #
8/1/2022	66456

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	8/1/2022			

Qty	Item Code	Description	Price Each	Amount
		Repair DH429473 1835 North Providence Road Media, PA 19063  Service date 8/1/22 Technician John Simons  Arrived on site to find panel indicating an alarm but there was no audible. The pump normal light was on but the pump running light was not. Perform meter check in found shorts on L1,L2 and manual from ground. Removed the lid to Station and found that the dry access was flooded. Removed DH429473 from station. Inspected the switchers and found that they were corroded. Remove control cover and found that the capacitor had leaked. Performed Meg test on motor, checked the stator and cutter wheel and they were all good. Replaced both switches and control clip. Returned the pump to station and tested from Alarm. The alarm panel went into alarm but the audible did not work. Replaced the buzzer in panel. Retested the alarm and it sounds properly. The alarm reset and the pump cycled and shut off. Job complete		
1	Service/Ins	Service Call & Inspection Fee <	150.00	150.00
2	Labor-JS	Labor rate for John Simons	110.00	220.00
1	Consumables	Includes nuts, bolts, washers, glue, tape, wire nuts, terminal flags, pipe dope, teflon tape, locktite, lubricants	0.00	0.00
1	1265	CONTROL BRACKET ASM, 240V/60HZ ND0045G01	0.00	0.00

All material remains the property of Site Specific Design until final payment.

**Total**

1704 Rockwell Road  
Abington, PA 19001  
215-887-3730

Date	Invoice #
8/1/2022	66456

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	JohnS	8/1/2022			

Qty	Item Code	Description	Price Each	Amount
1	6203	Seal, Level Sensing Housing Extreme NB0043P01	2.18306	2.18
1	7290	PRESSURE SWITCH ON/OFF EXTREME w/O-rings NB0083G01	38.185	38.19
1	7291	PRESSURE SWITCH, ALARM EXTREME w/ O-rings NB0083G02	38.185	38.19
1	9536	PA1717Po2 Buzzer, alarm, Sentry, 240V - no neutral panel	23.30376	23.30

All material remains the property of Site Specific Design until final payment.

**Total**

\$471.86

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.