

Date	Invoice #
8/5/2022	66508

Bill To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063

Ship To
Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via	Ref #	Project
	Net 30	PB	8/5/2022			

Qty	Item Code	Description	Price Each	Amount
1	Service/Ins	Replace DH433602 with Twp new core DH799235 210 Appletree Drive Media, PA 19063 Date of service 8/5/22 Technician Pat Brady Arrived on site and found pump DH433602 in high level alarm and not running all meter readings are incorrect. Megged the cable cable megs good. Pulled pump for further evaluation and found corroded switches, blown capacitor on the control bracket and motor megs bad. Installed a upper providence new core DH799235 and pump goes into and out of alarm and from on/off 32 seconds at 6.0 amps pump is running correctly		
2	Labor-PB	Service Call & Inspection Fee < Labor rate for Pat	150.00 110.00	150.00 220.00

All material remains the property of Site Specific Design until final payment.

Total

\$370.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.